



ZYRA E RREGULLATORIT PËR ENERGJI  
REGULATORNI URED ZA ENERGIJU  
ENERGY REGULATORY OFFICE

## **AMENDED ITEMS OF THE BALANCING CODE**

**February 2015**



## Approved amendments to the Grid code – Balancing Code

### Currently:

4.4.2.1 **Primary control** should begin immediately following a quazi steady-state frequency deviation of more than +/- 200 mHz, and take full effect not more than 30 seconds later.

### Amended to:

4.4.2.1 Activation of **Primary control** is accorded to begin before the frequency deviation exceeds  $\pm 20$  mHz against the nominal frequency. In case of a steady-state, when the frequency deviation of  $\pm 200$  mHz from the nominal frequency results, in these cases the entire reserve of the primary control must be completely activated not more than 30 seconds later.

### Currently:

4.5.1.2 For secondary control purposes the accuracy of local frequency control measurements must be within the range +/- 1 to 1.5 mHz.

### Amended to:

4.5.1.2 For secondary control purposes the accuracy of local frequency control measurements must be within the range +/- (1.0 mHz and 1.5 mHz).

In addition to these amendments, there were made also some minor amendments such as: insertion of items 2.6.1.6 and 2.6.1.7, linguistic improvements and text adjustments.

End of the Document