



ZYRA E RREGULLATORIT PËR ENERGJI  
REGULATORNI URED ZA ENERGIJU  
ENERGY REGULATORY OFFICE

## AMENDED ITEMS OF THE METERING CODE

**Shkurt 2015**



## Approved amendments to the Grid code – Metering Code

**Has been:**

7.1.1.7 For **metering** at the boundary of two or more **DSOs** the **DSO** whose network is electrically closer to the **transmission system** shall be responsible for the **metering system**.

**Amended to:**

7.1.1.7 For **metering** at the boundary of two or more **DSOs** one **DSO (in accordance with an agreement)**, or in a specific case the **DSO** whose network is electrically closer to the **transmission system** shall be responsible for the **metering system**

**In the part 2.1.1.1** Glossary and Definitions some terms have been redefined:

Force majeure,  
 Transmission System and Market Operator,  
 Distribution System Operator and  
 System User

**In the part 11.5.1.2** the table has been:

<u>Accuracy Standards for Site Tests</u>		<u>Percentage Error Limits of Meter</u>		
<u>Class of meter under test</u>	<u>Test Equipment Maximum Overall Uncertainty %</u>	<u>Uncompensated Active Meter</u>	<u>Compensated Active Meter</u>	<u>Reactive Meter</u>
<u>0.2</u>	<u>±0.2</u>	<u>±0.4</u>	<u>±0.5</u>	
<u>0.5</u>	<u>±0.2</u>	<u>±0.7</u>	<u>±0.7</u>	
<u>1.0</u>	<u>±0.6</u>	<u>±1.6</u>	<u>±1.6</u>	
<u>2.0</u>	<u>±0.6</u>	<u>±2.0</u>	<u>±2.0</u>	
<u>≤2.0</u>	<u>±1.0</u>			±2.5
<u>3.0</u>	<u>±1.5</u>			±3.5



*Amended to:*

<u>Accuracy Standards for Site Tests</u>		<u>Percentage Error Limits of Meter</u>		
<u>Class of meter under test</u>	<u>Test Equipment Maximum Overall Uncertainty %</u>	<u>Uncompensated Active Meter</u>	<u>Compensated Active Meter</u>	<u>Reactive Meter</u>
<u>0.2</u>	<u>±0.2</u>	<u>±0.4</u>	<u>±0.5</u>	
<u>0.5</u>	<u>±0.2</u>	<u>±0.7</u>	<u>±0.7</u>	
<u>1.0</u>	<u>±0.6</u>	<u>±1.6</u>	<u>±1.6</u>	
<u>2.0</u>	<u>±0.6</u>	<u>±2.0</u>	<u>±2.0</u>	
<u>≥2.0</u>	<u>±1.0</u>			±2.5
<u>3.0</u>	<u>±1.5</u>			±3.5

In addition to these there were made also some minor amendments such as: linguistic improvements and text adjustments.

End of the Document